



Certificate of Approval

Certificate No.:	SAA-140403-EA
Date of Issue:	7 April 2014
Certificate Holder:	People Ele. Appliance Group Co., Ltd. People Industry Zone, Liushi, Yueqing, Zhejiang, 325604 P.R. China
Class Description: Product Description:	Residual Current Device Residual Current Operated Circuit Breaker (RCCB)
Brand Name:	
Model No.:	PID-63
Markings:	$U_n=240V\sim(1P+N)$ $I_n=16, 25, 32, 40, 50, 63A$ $I_{\Delta n}=0.03, 0.1, 0.3A$ Type A and AC $I_{nc}=I_{\Delta c}=6000A$
Standard:	AS/NZS 61008.1:2011
Conditions:	Nil
Approval Mark:	SAA-140403-EA or RCM
Date First Registered:	20 March 2014
Date of Expiry:	20 March 2019



For and on Behalf of
SAA Approvals Pty Ltd

Reissued to correct Standard.

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



140403/1a